

Q: Please change to say – The filter to be able to handle 45 mg/l TSS for 2-3 hours and maintain a ≤ 15 mg/l TSS.

A: We will not be able to accommodate this request.

Q: If so please change to filter not to exceed 8”.

A: meet normal flow conditions

Q: Can the Note after section J. at the bottom of page be changed to say the proposed filter system shall be furnished and installed by the equipment manufacturer?

A: We will not be able to accommodate this request.

Q: time and trips listed in part A. can be reduced to 2 trips for a total of 6 days on-site for start-up and training.

A: we will consider a reduced trip count

Q: Can the Contract Time line be changed to 240 days?

A: reference addenda #2

Q: Are the slide gates to be replaced completely? If not, what parts are to be replaced? Please provide the manufacture and model of the existing slide gates.

A: able to be removed and replaced

Q: Why is this sentence included? Is there railroad property related to this project? If not please remove from the spec. If so, what limits of insurance will be required by the railroad company? Would they be different from limits required by the City that are listed in the RFP?

A: Disregard this item of the document